



Sertifikat Certificate

SERTIFIKAT

O PREGLEDU TIPa / Type examination

Broj / Number: T 1819

POJEDINAČNI PREGLED / Single examination

Strana / Page: 1 / 2

Na zahtev naručioca /
By the request of purchaser: **Robert Bosch d.o.o. Milutina Milankovića 9ž**
11070 Beograd Srbija / Serbia

preduzeto je/
has been undertaken: **Kontrolisanje novog proizvoda**
the new product inspection

u vezi sa Izveštajem o usaglašenosti/
in relation to Inspection report:

Broj /
Number: T 1819

sa dokumentima u prilogu /
with attached documents:

- Uputstvo za korišćenje / User's manual
- Uputstvo za instaliranje / Installation instruction;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaji o ispitivanju DVGW B18/03/2622 EU i B18/03/2623 EU; / Test reports DVGW B18/03/2622 EU and B18/03/2623 EU

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /
subject of the inspection: **GASNI KOTAO /**
GAS BOILER

proizveden od /
manufactured by: **Bosch Thermotechnik Isitma ve Klima San ve Tic A.S.**
Organize Sanayi Bölgesi TR-45030 Manisa Turkey

oznaka - tip - serija /
mark - type - series: **BOSCH Condens 7000 iW ...**

vrsta/type: **B₂₃, C₁₃, C₃₃**
kategorija/category: **II_{2H3B/P}**

kako je specificirano u Prilogu
A, zadovoljava zahteve
navedene u /
as specified in the Annex A, meets
the requirements listed in:

Pravilnik o zahtevima za projektovanje, izradu
i ocenjivanje usaglašenosti gasnih aparata ("Sl.
gl. RS", br. 41/2015) / Regulations on
Requirements for design, construction and mark
the conformity of gas appliances SG RS 41/15

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i
Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012
and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs

izdat od / issued by:

INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE
Kristina Petković dipl.maš.inž.

mesto, datum / place, date:

Beograd, 11.06.2018.



Ime, Prezime / Name, Surname

Prilog A /
Annex A

Broj /
 Number: **T 1819**
 Strana /
 Page: **2 / 2**

oznaka - tip - serija /
 mark - type - series :

BOSCH Condens 7000 iW...

vrsta/type: **B₂₃, C₁₃, C₃₃**
 kategorija/category: **II_{2H3B/P}**

Sertifikat
Certificate



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
 Volgina 15,
BEOGRAD SRBIJA
 tel: +381 11 6772 151
 fax: +381 11 6781-02
 impcgt@pupin.rs

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
BOSCH Condens 7000 iW...		
GC7000 iW 14 PB 23 GC7000 iW 14 P 23	Q _n =2,1÷14,4 kW P _n =2,0÷14,0 kW ^{1.)} P _n =2,2÷15,0 kW ^{2.)}	za grejanje i povezivanje na spoljni bojler za TSV/ for heating and connecting to an external drinking water storage for DHW
GC7000 iW 24 PB 23 GC7000 iW 24 P 23	Q _n =3,1÷24,6 kW P _n =3,0÷34,0 kW ^{1.)} P _n =3,3÷25,1 kW ^{2.)}	
GC7000 iW 35 PB 23 GC7000 iW 35 P 23	Q _n =5,2÷33,8 kW P _n =5,0÷28,4 kW ^{1.)} P _n =5,6÷30,0 kW ^{2.)}	
GC7000 iW 42 PB 23 GC7000 iW 42 P 23	Q _n =5,5÷41,0 kW P _n =5,3÷39,9 kW ^{1.)} P _n =5,9÷42,0 kW ^{2.)}	
GC7000 iW 20/24 CB 23 GC7000 iW 20/24 C 23	Q _n =3,1÷20,5 kW Q _{nTSV} =3,1÷24,6 kW ^{3.)} P _n =3,0÷20,0 kW ^{1.)} P _n =3,4÷21,4 kW ^{2.)}	- za grejanje i pripremu tople sanitarne vode (TSV) sa ugrađenim primarnim izmenjivačem/ for heating and preparation of domestic hot water (DHW) with built-in plate heat exchanger
GC7000 iW 24/28 CB 23 GC7000 iW 24/28 C 23	Q _n =3,8÷24,6 kW Q _{nTSV} =3,8÷28,7 kW ^{3.)} P _n =3,7÷24,0 kW ^{1.)} P _n =4,1÷25,1 kW ^{2.)}	
GC7000 iW 30/35 CB 23 GC7000 iW 30/35 C 23	Q _n =5,2÷29,0 kW Q _{nTSV} =5,2÷33,8 kW ^{3.)} P _n =5,0÷28,4 kW ^{1.)} P _n =5,6÷30,0 kW ^{2.)}	

Napomene / notes:

- 1.) pri / at 80/60°C;
- 2.) pri / at 50/30°C ;
- 3.) za toplu sanitarnu vodu TSV / for domestic hot water (DHW)

Bilo kakve promena na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document