



KOVINSKO PREDELOVALNO PODJETJE d.d.
 ODDELEK ZA ZAGOTAVLJANJE KAKOVOSTI
 Grmaška cesta 3, 1275 Šmartno pri Litiji
 Tel.: +386 01 8962-100, 8962-162
 Fax.:+386 01 8962-140

CERTIFICATE OF QUALITY

Name of product: **Ball valve for gas DVGW (type K 970)**

Application: ...It can be used for gas installations nach DIN DVGW

Mark of product:.....KV 302TAS, KV 303TAS, KV 304TAS,

Size of product:1/2", 3/4", 1",

Number of consignment:...

TEHNICAL SPECIFICATION			
Construction parts	Material	Mark	Standard
body	Pressed brass	CuZn39Pb2	DIN 17660
ball	MS 58	CuZn39Pb3	DIN 17672
spindle			
body TAS	stell		K84-331
ball seals	O-ring	NBR 80 ShA	
spindle seals	O-ring	NBR 70 ShA	DIN 3771
handle	stell plate	R St44 -2	DIN 17100
Thread connections "Rp" are made for pipe connections according to DIN 2999.			

Base size:after catalogue

Nominal pressure:from 0 to 5 bar

Work temperature:from -10°C to + 60°C

Max. temperature (body TAS): 925°C for minimum time 60 min

Test medium:air

Test pressure:7,5 bar

REMARK: Certificate is valid only for ball valves marked by sign

Valid for two years.

Šmartno pri Litiji , 11.02.2009

Manager of quality department:

Darjan Knežević

[Handwritten signature]

OB 1003-4