



SERTIFIKAT

O PREGLEDU TIPA/ Type examination

Broj / Number: T 2211

POJEDINAČNI PREGLED/Single examination

Strana / Page: 1 / 2

Na zahtev naručioca / By the request of purchaser: **ETAŽ d.o.o. Šumatovačka 2, 11224 Vrčin - Beograd, Srbija / Serbia**

preduzeto je/ has been undertaken: **Kontrolisanje novog proizvoda / Inspection of the new product**

u vezi sa Izveštajem o usaglašenosti/ in relation to Inspection report:

Broj / Number: T 2211

sa dokumentima u prilogu/ with attached documents:

- Uputstvo za instaliranje, održavanje i korisnika / Installation, maintenance instructions and User manual;
- Dokumentacija ugrađenih komponenti / Documentation of embedded components;
- Izveštaji o ispitivanju IMP CGT T 2211; Testing Laboratory LVT 20-1730-R0-N1-1; INTEGRA96 ULUSLARARASI ÜRÜN VE SİSTEM BELGELENDİRME BAĞIMSIZ DENETİM GÖZETİM EĞİTİM HİZMETLERİ LTD. ŞTİ. M7161 / Test reports IMP CGT T 2211; Testing Laboratory LVT 20-1730-R0-N1-1; INTEGRA96 ULUSLARARASI ÜRÜN VE SİSTEM BELGELENDİRME BAĞIMSIZ DENETİM GÖZETİM EĞİTİM HİZMETLERİ LTD. ŞTİ. M7161

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da: INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja / subject of the inspection: **GASNI KONDENZACIONI KOTAO / GAS CONDENSING BOILER**

proizveden od / manufactured by: **BESTHERM IKLIMLENDİRME SANAYI VE TIC A.Ş -ISIKTEPE OSB MH.75.YIL BLV 2.SK N:4 Bursa Turkey / Turska**

oznaka - tip - serija / mark - type - series: **CENTROMETAL Gas Tec...**
vrsta/type: **B₂₃, B₃₃, C₁₃, C₂₃, C₃₃, C₄₃, C₆₃, C₅₃, C₈₃, C₉₃**
kategorija/category: **II_{2H3B/P}**

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u / as specified in the Annex A, meets the requirements listed in:

- Pravilnik o zahtevima za projektovanje, izradu i ocenjivanje usaglašenosti gasnih aparata ("Sl. gl. RS", br. 41/2015)
- SRPS EN 15502-2-1:2017

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 / The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012 and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.

Ocenjivanje sprovedeno / Evaluation performed from 23.03. - 05. 05. 2022..

izdat od / issued by:

**INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE
Kristina Petković dipl.maš.inž.**

mesto, datum izdavanja / place, date of issue:

Beograd, 05. 05. 2022.



Ime, Prezime / Name, Surname

Sertifikat Certificate



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impct@pupin.rs



SERTIFIKAT

O PREGLEDU TIPa/ Type examination

POJEDINAČNI PREGLED/Single examination

Prilog A /

Broj / Number: T 2211

Annex A

Strana / Page: 2 / 2

oznaka - tip - serija /
mark-type-series:

CENTROMETAL Gas Tec...

vrsta/type: B₂₃, B₃₃, C₁₃, C₂₃, C₃₃, C₄₃, C₆₃, C₅₃, C₈₃, C₉₃

kategorija/category: II_{2H3B/P}

Sertifikat
Certificate

detaljno oznaka - tip - serija mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description:	
CENTROMETAL Gas Tec...			
... 20	Q _n = 4,2 ÷ 20,1 kW P _n = 4,1 ÷ 19,7 kW* P _n = 4,5 ÷ 21,1 kW**	G20: p = 20 mbar, G30 : p = 30 mbar, NOx class 6	za grejanje i pripremu tople sanitarne vode (TSV) / for heating and preparation of domestic hot water (DHW)
... 24	Q _n = 4,3 ÷ 24,1 kW P _n = 4,1 ÷ 23,6 kW* P _n = 4,5 ÷ 25,5 kW**	PMS = 3 bar, MPW = 9 bar t _{CH} = 85 °C	
... 35	Q _n = 4,8 ÷ 27,5 kW P _n = 4,7 ÷ 27,0 kW* P _n = 5,2 ÷ 29,1 kW**	t _{DHW} = 65 °C IPX4D 230V, 50Hz, 95W	
Napomene/ Notes: * za / for 80 ÷ 60 °C ** za / for 50 ÷ 30 °C			
Bilo kakva promena na uređaju mora se prijaviti izdavaocu ove isprave. / Any changes on the device must be reported to the issuer of this document			
Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one year within the assessment of the Declaration of Conformity with the type!			



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs